

COMMONWEALTH OF PENNSYLVANIA  
 DEPARTMENT OF ENVIRONMENTAL PROTECTION  
 BUREAU OF SAFE DRINKING WATER

**2025 ANNUAL DRINKING WATER QUALITY REPORT**
**PWSID #: 5020047 NAME: Reserve Township**

*Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda.* (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

**WATER SYSTEM INFORMATION:**

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Jan Kowalski, CPA, Township Manager at 412-322-1551. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the first Wednesday of each month (unless otherwise advertised) at 7:00PM at the Township Offices, 33 Lonsdale Street, Pittsburgh PA 15212.

**SOURCE(S) OF WATER:**

Reserve Township purchases water from Pittsburgh Water (Pgh2o), which treats water from the Allegheny River.

We do not use ground or well water

A Source Water Assessment of Pittsburgh Water's intake water was completed by the PA Department of Environmental Protection (PA DEP). The Assessment has found that our source water is potentially most susceptible to road deicing materials, accidental spills along railroad tracks, and leaks from submerged pipelines and storage tanks. Overall, the Allegheny River watershed has a moderate risk of significant contamination. Complete reports were distributed to municipalities and water suppliers.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

**Monitoring Your Water:**

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2025. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

**DEFINITIONS:**

*Action Level (AL)* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Minimum Residual Disinfectant Level (MinRDL)** - The minimum level of residual disinfectant required at the entry point to the distribution system.

**Level 1 Assessment** – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment** – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.

*Mrem/year* = millirems per year (a measure of radiation absorbed by the body)

*pCi/L* = picocuries per liter (a measure of radioactivity)

*ppb* = parts per billion, or micrograms per liter (µg/L)

*ppm* = parts per million, or milligrams per liter (mg/L)

*ppq* = parts per quadrillion, or picograms per liter

*ppt* = parts per trillion, or nanograms per liter (ng/L)

#### **DETECTED SAMPLE RESULTS:**

<b>Chemical Contaminants-Reserve Township Distribution System</b>								
<b>Contaminant</b>	<b>MCL in CCR Units</b>	<b>MCLG</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>Units</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
HAA5	60	N/A	18	11-28	ppb	2025	N	By-product of drinking water disinfection
TTHM	80	N/A	66	20-126	ppb	2025	N	By-product of drinking water disinfection
Free Chlorine	4.0	MRDLG -4	1.17	0.27-1.17	ppm	2025	N	Water additive used to control microbes

<b>Chemical Contaminants- Pittsburgh Water</b>								
<b>Contaminant</b>	<b>MCL in CCR Units</b>	<b>MCLG</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>Units</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Nitrate	10	10	0.62	0.43-1.08	ppm	2025	N	Runoff from fertilizer use; industrial or domestic wastewater discharges; erosion of natural deposits
Barium	2	2	0.028	N/A	ppm	5/5/2025	N	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Fluoride	4	2*	0.776	N/A	ppm	5/5/2025	N	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Calcium	N/A	N/A	26	21-31	ppm	2025	N	N/A
HAA5	60	N/A	15	7-24	ppb	2025	N	By-product of water disinfection
TTHM	80	N/A	51	12-112	ppb	2025	N	By-product of water disinfection
Orthophosphate	N/A	N/A	1.85	1.52-2.13	ppm	2025	N	Corrosion Control Additive
Iron	N/A	N/A	0.016	0-0.075	ppm	10/2/2024	N	N/A

\*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health.

<b>Entry Point Disinfectant Residual – Pittsburgh Water</b>							
<b>Contaminant</b>	<b>Minimum Disinfectant Residual</b>	<b>Lowest Level Detected</b>	<b>Range of Detections</b>	<b>Units</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Free Chlorine	0.20	0.30	0.30-1.08	ppm	2025	N	Water additive used to control microbes.

<b>Lead and Copper-Reserve Township Distribution System</b>								
Contaminant	Action Level (AL)	MCLG	90 <sup>th</sup> Percentile Value	Range of tap sampling results	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	15	0	0	0-2.6	ppb	0	N	Corrosion of household plumbing.
Copper	1.3	1.3	0.073	0.007-0.081	ppm	0	N	Corrosion of household plumbing.

<b>Turbidity</b>						
Contaminant	MCL	MCLG	Level Detected	Sample Date	Violation Y/N	Source of Contamination
Turbidity	TT=1 NTU for a single measurement	0	0.150	5/2/2025	N	Soil runoff
	TT= at least 95% of monthly samples $\leq$ 0.3 NTU		100%	N/A	N	

<b>Total Organic Carbon (TOC)</b>					
Contaminant	Range of % Removal Required	Range of percent removal achieved	Number of quarters out of compliance	Violation Y/N	Sources of Contamination
TOC	25%-35%	42%-54%	0	N	Naturally present in the environment

**OTHER VIOLATIONS:** *There were no violations for 2025*

**EDUCATIONAL INFORMATION:**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some

contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

### **Information about Lead**

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Reserve Township is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. In Reserve Township the customer's service line extends from the home to the main water line, including the portion between the curb stop and the main line. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to find out information on how to have your water tested, contact Reserve Township Water Department. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

### ***OTHER INFORMATION:***

Reserve Township prepared a service line inventory of our system that includes the type of materials contained in each service line in our distribution system. This inventory can be accessed online at <https://reservetwp.com> or by contacting our office at 412-322-1551.